



Hirani Group

# Hirani Engineering & Land Surveying, P.C.

Engineers ■ Land Surveyors ■ Construction Managers

30 Jericho Executive Plaza, Suite 200C • Jericho, NY 11753 • 516-248-1010 • Fax: 516-248-9018

***Confidential: the contents of this document are confidential and intended solely for the recipient. Reproduction of or forwarding to anyone not directly sent this document is strictly forbidden.***

March 20, 2017

Mr. Richard Lenz  
Commissioner  
Department of Public Works  
150 Miller Place  
Syosset, New York 11791-5699

Re: Hicksville Garage  
Hicksville, New York

Dear Mr. Lenz,

Hirani Engineering & Land Surveying, P.C. was contracted by the Town of Oyster Bay to inspect the cracks in the Hicksville Parking Garage, located at 55A Duffy Avenue, Hicksville. Based on our visual inspection of the garage, two major through cracks each in the Ground and Lower Level 1 slab decks constituted a safety concern and therefore were recommended to be shored.


As of today March 20, 2017, most of the shoring in the active driving lanes on the aforementioned slabs and ramps have been installed. The affected areas in the parking quarters/zones in the vicinity of these cracks (approximately 96 parking spots) have been cordoned off and installation of shoring for those areas is in progress.

Based on these measures taken, the parking garage structure is safe for public use with the restrictions imposed (parking in cordoned areas is not permitted).

Shoring design drawings will be submitted under separate cover to reflect the temporary shoring installed with any proposed changes if or where required. To ensure public safety, it is assumed that the Town will provide safety measures, as deemed necessary, (including but not limited to safety cones, signs and personnel) to regulate the flow of movement in the garage.

Please contact our office if you have any questions or require additional information.

Regards,  
Hirani Engineering and Land Surveying, P.C.

  
Jitendra S. Hirani, P.E.  
President

